

Consumer Confidence Report

Annual Drinking Water Quality Report

FAYETTE WATER COMPANY

IL0510010

Annual Water Quality Report for the period of January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by FAYETTE WATER COMPANY is Groundwater and Purchased Surface Water

For more information regarding this report contact:

Name **Dennis Vaughn**

Phone **(618) 427-3000**

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact **Fayette Water Company** at **(618) 427-3000**. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Source Water Information

Source Water Name		Type of Water	Report Status	Location
CC01 - CONNECTION TO GATEWAY	FF IL0270040 TP01	SW	Active	800N & 1100E
CC03 - CONNECTION TO EJ WATER COOP	FF IL0790010 TP03	SW	Active	ILL RTE 128 & 2800N
WELL 2 (01013)		GW	Active	Sefton Twp
WELL 4 (01015)	625 FT N OF WELL 2	GW	Active	Sefton Twp
WELL 5 (01533)	1850 FT S OF WELL 2	GW	Active	Sefton Twp
WELL 6 (01818)	895 FT NE OF WELL 2	GW	Active	FAYETTE COUNTY, SEFTON TOWNSHIP SE 1/4 OF THE NW 1/4 OF THE SW 1/4 OF SEC 32, T8N, R2E
WELL 7 (01858)	210 FT S OF WELL 5	GW	Active	Sefton Twp

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at (618) 427-3000. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: FAYETTE WATER COMPANY To determine Fayette Water Company's susceptibility to groundwater contamination, a potential source inventory done by Illinois Rural Water Association was reviewed by the Illinois EPA. Based on the information contained in this document, no potential sources of groundwater contamination are present that could pose a hazard to groundwater pumped by the Fayette Water Company community water supply wells. The Illinois EPA has determined that Fayette Water Company Wells #2, #3, and #4 are susceptible to IOC, VOC, and SOC contamination. This determination is based on a number of criteria including: agricultural land use; monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and the available hydrogeologic data for the wells. Source of Water: GATEWAY REGIONAL WATER COMPANY Illinois EPA considers all surface water sources of community water supply to be susceptible to potential pollution problems, hence, the reason for mandatory treatment for all surface water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration, and disinfection. Primary sources of pollution in Illinois lakes can include agricultural runoff, land disposal (septic systems) and shoreline erosion. Source of Water: EJ WATER COOP To determine E J Water Corporation's susceptibility to groundwater contamination, the Illinois EPA reviewed a Well Site Survey, published in 1996 by the Illinois EPA, a Source Water Protection Management Plan, prepared by the facility's planning committee and published in 1997, and a survey of the south well field performed in 2005. Based on the above documents, the community water supply's source water is susceptible to IOC and SOC contamination from non-point sources related to agricultural land use, although no presence of any pesticides/herbicides were detected in any water samples thus far analyzed. As a result of monitoring conducted at the wells and entry point to the distribution system, the land use activities, and source water protection initiatives by the facility, the E J Water Corporation's groundwater source is not susceptible to VOC contamination. However, Illinois EPA considers all surface water sources of public water supply to be susceptible to potential pollution problems. Hence the reason for mandatory treatment of all public water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration and disinfection.

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
na:	not applicable.
mrem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

2025 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: <50 to 5510 ppb (Distribution); <50 to 61.9 ppb (DS-SW1); <50 ppb (DS-SW3)

Lead Range: <5 to 5.87 ppb (Distribution); <5 ppb (DS-SW1); <5 ppb (DS-SW3)

To obtain a copy of the system's lead tap sampling data: Contact Fayette Water Company at (618) 427-3000 or Visit the office at 1745 N. 1615 Street Brownstown, IL 62418

CIRCLE ONE: Our Community Water Supply has / has not developed a service line material inventory.

To obtain a copy of the system's service line inventory: Contact Fayette Water Company at (618) 427-3000 or Visit the office at 1745 N. 1615 Street Brownstown, IL 62418

Lead and Copper Distribution	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2024	1300	1300	873	2	ppb	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2024	0	15	0	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Lead and Copper DS-SW1	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2024	1300	1300	0	0	ppb	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2024	0	15	0	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Lead and Copper DS-SW3	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2025	1300	1300	0	0	ppb	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2025	0	15	0	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Distribution - Area of the system provided with water from the FWC Water Treatment Plant.

DS-SW1 - Area of the system provided with water from Gateway Regional Water Company (South of I-70).

DS-SW3 - Area of the system provided with water from EJ Water Cooperative (Areas North and East of St Elmo).

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2025	2.7	2 - 3	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAAS)	2025	66	5 - 78.7	No goal for the total	60	ppb	Y	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2025	78	11.3 - 100.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	07/10/2023	0.0694	0.0694 - 0.0694	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	07/10/2023	0.55	0.55 - 0.55	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Iron	07/10/2023	0.0684	0.0684 - 0.0684		1.0	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Manganese	07/10/2023	47.6	47.6 - 47.6	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Sodium	07/10/2023	31700	31700 - 31700			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	12/09/2020	0.52	0.52 - 0.52	0	5	pCi/L	N	Erosion of natural deposits.

Violations Table

Haloacetic Acids (HAA5)			
Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MCL, LRAA	10/01/2025	12/31/2025	Water samples showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated. FWC received a violation for Haloacetic Acids (HAA5) which is a portion of our Disinfection By-Products sampling. This violation only affects that part of the FWC system which receives water treated from our Water Plant. FWC has been collecting samples through out the system to help determine the cause and to provide a solution in eliminating any future exceedances. FWC is striving to be in compliance by April 2027 and has entered into a Compliance Commitment Agreement with IEPA.

PCBs [Polychlorinated biphenyls]			
Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or reproductive or nervous system difficulties, and may have an increased risk of getting cancer.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated. IEPA did not receive any test results for this contaminant during the sampling period of Jan. 1, 2023 to Dec. 31, 2025. The contaminant was tested for in February 2026 with the results given to IEPA. We achieved compliance with IEPA on April 3, 2026.

Public Notification Rule			
The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).			
Violation Type	Violation Begin	Violation End	Violation Explanation
PUBLIC NOTICE RULE LINKED TO VIOLATION	12/25/2025	01/28/2026	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations. FWC did not provide a public notice within the time frame set by IEPA for the Haloacetic Acids (HAA5) violation. To achieve compliance FWC placed a notice on the water bills sent on Jan. 27, 2026 directing the customers to the public notice posted on our website. We achieved compliance with IEPA on Jan. 28, 2026.

Regulated Contaminants (EJ Water Cooperative)

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2025	0.0042	0.0042 - 0.0042	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2025	0.4	0.413 - 0.413	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2025	0.36	0.18 - 0.38	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	2025	12	12 - 12			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	07/07/2021	0.189	0.189 - 0.189	0	5	pCi/L	N	Erosion of natural deposits.
Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine	2025	1	0 - 0.48	3	3	ppb	N	Runoff from herbicide used on row crops.

Turbidity

	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	1 NTU	0.208 NTU	N	Soil runoff.
Lowest monthly % meeting limit	0.3 NTU	100%	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

Regulated Contaminants (Gateway Regional Water Company)

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2025	2	1.72 - 1.9	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	2025	0.0663	0.048 - 0.0663	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2025	0.8	0.73 - 0.773	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Manganese	2025	3	0 - 6.1	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2025	0.26	0.24 - 0.26	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	2025	24	28 - 19100			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	01/06/2020	0.14	0.14 - 0.14	0	5	pCi/L	N	Erosion of natural deposits.
Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine	2025	1	0.43 - 0.84	3	3	ppb	N	Runoff from herbicide used on row crops.
Simazine	2025	0.38	0 - 0.38	4	4	ppb	N	Herbicide runoff.

Regulated Contaminants(continued)

Turbidity

	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	1 NTU	0.25 NTU	N	Soil runoff.
Lowest monthly % meeting limit	0.3 NTU	100%	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.
